

## MATERIAL TESTING LABORATORY Page No: 01 MILITARY ENGINEER SERVICES (MES) Copy no: 01 TEST RESULT FOR FINENESS MODULUS(F.M.) OF SAND.

Job No : 01/2025-2026 (Sand). Name of Clint : GE (Air) Tejgaon, Dhaka.

Ref ltr no : CE (Air)/164 of 2024-2025/03/E-6 Dt.30 Jun'2025

Project Name : Construction of Water Reservoir.

Sample Specimen : Sylhet Sand. Dt of sample collection : 01 July'2025

Test Standard: ASTM/BS

Sieve Size	Wt of Material	Percentage Matarial	Cumulative % Retained	%Finer	Remarks
516 46 5126	Retainned(gms)	Retained(Round)	camalative /s netained	701 IIIC1	Remarks
# 4	1.7	0.43	0.43		
# 8	25.61	6.40	6.83		
#16	64.82	16.21	23.03		
# 30	164.2	41.05	64.08		
# 50	121.32	30.33	94.41		FM= 2.88
#100	19.29	4.82	99.24		
# 200	2.38	0.60			
#Pan	0.53	0.13			
			Σ= 288.02		

## Cautions:

- 1 Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative character of the sample to be tested.
- 2 It is recommended that samples are sent in a sealed cover/packet/container under signature of the competent authority
- 3 In oder to be avoid fraudulent fabrication of the test result, it is recommended that test reports should be collected by duly authorized person and not by the contractor/supplier.

## Observation on Specimen(if any):

1

<u>Laboratory Technician</u> <u>Test Performed By</u> <u>Vetted By</u>

## Permissable Value:

1.For Sylhet/Domar sand minimum FM will be = 2.50

2.For Local sand minimum FM will be = 1.5

3.For Vitty sand minimum FM will be = 0.80