

## MATERIAL TESTING LABORATORYPage No : 249MILITARY ENGINEER SERVICES (MES)Copy no : 02

## TEST RESULT FOR COMPRESSIVE STRENGTH OF CONCRETE CYLINDER/CUBE

Job No : 142/2025-2026 (Con).

Name of Client : GE (Army) Savar. Sample Specimen: Ht 200mm(8") Dia 100 mm(4")

Ref ltr no : EinC/24 of 2024-2025/25 /E-6 Dt.07 Sep'2025. Type of Aggregate : Stone

Name of the project : Construction of 1x Sub-Station Bldg. Brand &Type of Cement : Metrocem Opc.

Status of sample : Foundation. Proportion of Mixture : 1:1.5:3

Dt of sample collection: 08 Sep'2025 Desired Design Strength : 3500 Psi

Test Standard : ASTM/BS

Ser no.	Date of casting	Date of Test	Specimen	Maximum Load	Crushing	Average	Remarks
	and		Area	(Lbs)	Strength	Crushing	
	(Age in days)		Sq inch		(Psi)	Strength	
						(Psi)	
1			12.17	46965.84	3859	Average of	
2	04 Sep'2025 (28 days)	02 Oct'2025	12.17	46145.68	3792	Sample 1 & 2	Combined Failure
3			12.17	56511.60	4644	3825	

## Cautions:

- 1 Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative character of the sample to be tested.
- 2 It is recommended that samples are sent in a sealed cover/packet/container under signature of the competent authority
- In oder to be avoid fraudulent fabrication of the test result, it is recommended that test reports should be collected by duly authorized person and not by the contractor/supplier.

## Observation on Specimen(if any):

1

<u>Laboratory Technician</u>	<u>Test Performed By</u>	<u>Vetted By</u>