

## MATERIAL TESTING LABORATORY Page No: 174 MILITARY ENGINEER SERVICES (MES) Copy no: 01 TEST RESULT FOR FINENESS MODULUS(F.M.) OF SAND.

Job No : 97/2024-2025(Sand).

Name of Clint : AGE (Air) PKP.

Ref ltr no : EinC/444 of 2022-2023/40/E-6 Dt.22 May'2025

Project Name : Construction of Boundary wall.

Sample Specimen : Sylhet sand Dt of sample collection : 28 May'2025

Test Standard : ASTM/BS

| Sieve Size | Wt of Material | Percentage Matarial | Cumulative % Retained | %Finer | Remarks  |
|------------|----------------|---------------------|-----------------------|--------|----------|
|            | Retainned(gms) | Retained(Round)     |                       |        |          |
| # 4        | 0              | 0.00                | 0.00                  |        |          |
| # 8        | 22.99          | 5.75                | 5.75                  |        |          |
| #16        | 145.55         | 36.39               | 42.14                 |        |          |
| # 30       | 162.98         | 40.75               | 82.88                 |        |          |
| # 50       | 60             | 15.00               | 97.88                 |        | FM= 3.29 |
| #100       | 8.44           | 2.11                | 99.99                 |        |          |
| # 200      | 0.02           | 0.01                |                       |        |          |
| #Pan       | 0.18           | 0.05                |                       |        |          |
|            |                |                     | Σ= 328.63             |        |          |

## Cautions:

- 1 Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative character of the sample to be tested.
- 2 It is recommended that samples are sent in a sealed cover/packet/container under signature of the competent authority
- In oder to be avoid fraudulent fabrication of the test result, it is recommended that test reports should be collected by duly authorized person and not by the contractor/supplier.

## Observation on Specimen(if any):

1

**Laboratory Technician** 

Test Performed By

Vetted By

## Permissable Value:

1.For Sylhet/Domar sand minimum FM will be = 2.50

2.For Local sand minimum FM will be = 1.5

3.For Vitty sand minimum FM will be = 0.80